



BRUHATH BENGALURU MAHANAGARA PALIKE
MEDICAL OFFICER OF HEALTH, BOMMANAHALLI ZONE, 2ND FLOOR, BDA COMPLEX,
HSR LAYOUT, BENGALURU-102

No:BBMP/MOH(BZ)/PR/165/23-24


Date:25/03/2024

TO WHOM SO EVER IT MAY CONCERN
SAFE DRINKING WATER AND SANITATION CONDITION
CERTIFICATE

This is to Certify that an Inspection team headed by MOH from Health Department of Bruhath Bengaluru Mahanagara Palike, Bommanahalli Zone, inspected the **NATIONAL PUBLIC SCHOOL, No.148, Silvar County Road, Kudlu, Bangalore-560068**. Has Safe drinking water facilities for the students and staff members of the institution with RO Water filter and is maintaining the Hygenic Sanitation Condition in the School Building and the campus as per the norms prescribed by the state Government.

The above valid for a period of One year,

To;
Principal,
NATIONAL PUBLIC SCHOOL,
No.148, Silvar County Road,
Kudlu, Bangalore-560068


ಆರೋಗ್ಯ ವೈದ್ಯಾಧಿಕಾರಿ
Medical officer of Health
ಬೊಮ್ಮನಹಳ್ಳಿ ವಲಯ
Bommanahalli Zone
ಬಿ.ಕೆ.ಎಸ್. ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

No:PHI/Water/BAC/ 1032/23-24

GOVERNMENT OF KARNATAKA

Office of the Joint Director
Public Health Institute
Bengaluru - 560 001

Report of Bacteriological analysis of Water/Effluent sample

Dated: 11/03/2024

Sample No.	Source & Particulars of Water Sample	Opinion					
		M.P.N Count	Plate Count	D.C Test	S.P.P	N.S.P.P	N.S.P.P & FC.
3258	B.NO-4429957	NIL	-	-	SPP	-	-

Note:
M.P.N Count:
Most probable number of Bacteria per 100ml of Water
D.C Test:
Differential Coliform test
Plate Count:
Plate Count per ml of sample
SPP:
Water is satisfactory for Potable purpose
NSPP:
Water is not satisfactory for Drinking purpose
NSPP & FC:
Water is not satisfactory for Drinking purpose and E.Coli found

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE
Bengaluru
(PRO)

Advice:

1. Sample.....
Need effective chlorination before use
2. Sample.....

Need to avoid possible source of faecal contamination and effective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform count per 100ml	E coli count per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More